


**SECTION 260500 - GENERAL ELECTRICAL**



**PART 1 GENERAL**

All 26xxxx & 27xxxx Sections

**1.1 SCOPE OF WORK**

- A. The Instructions to Bidders, General Conditions of the Contract, Supplementary General Conditions and Division 1 bound herewith are a component part of this Division of the specifications and shall apply to this Division with equal force and shall be consulted in detail for instructions pertaining to the work.
- B. Furnish all labor, materials and equipment and incidentals required to make ready for use complete electrical systems as shown on the Drawings and specified herein.
- C. It is the intent of these Specifications that the electrical systems shall be suitable in every way for the service required. All material and all work which may be reasonably implied as being incidental to the work of this Division shall be furnished at no extra cost.
- D. The work shall include, but not be limited to, furnishing, coordinating, and installing the following:
  - 1. Modifications and additions to the existing electrical lighting systems as shown on the contract drawings, complete with indicated switching, circuiting, etc.
  - 2. Electrical receptacle system modifications and extensions as shown on the contract drawings.
  - 3. Empty raceway and outlet system for telecommunications, data and other special systems.
  - 4. Grounding.
  - 5. Other special requirements and/or systems where shown.
- E. Each bidder (or Representative) shall, before preparing a proposal, visit all areas of the existing site. If the work includes demolition, restoration, renovation and/or addition; then existing buildings and structures should be carefully inspected. The submission of the proposal by this Bidder shall be considered evidence that the Bidder (or Representative) has visited the site and noted the locations and conditions under which the work will be performed and that the Bidder takes full responsibility for a complete knowledge of all factors governing the work.
- F. All power interruptions to existing equipment shall be at the Owner's convenience with 24 hours (minimum) notice. Each interruption shall have prior approval.
- G. The work shall include complete testing of all equipment and wiring at the completion of work and making any minor correction changes or adjustments necessary for all the proper functioning of the system and equipment. All work shall be of the highest quality; substandard work will be rejected.
- H. Field verify all existing underground electrical and mechanical piping.

## 1.2 SUBMITTALS

- A. Shop drawings shall be submitted for all equipment, apparatus, and other items as required by the Architect/Engineer. Submit under provisions of relevant sections of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Submittals are required for all materials shown in the individual specifications sections.
- C. Submittals are required for materials used for penetrations of rated assemblies and for seismic restraints.
- D. Transmit each shop drawing submittal with provided Shop Drawing Submittal Cover Form, attached, for each item of equipment/material or each specification section/paragraph.
- E. All shop drawings and submittals shall be submitted at the same time. Partial shop drawing and submittals will be rejected and not processed. Materials, equipment and long lead items that require special handling, if identified and requested by the contractor, will be processed separately.
- F. Proposed equipment and/or materials substitutions shall be clearly indicated in shop drawings. All deviations from the specified quality, functionality, appearance or performance of the proposed equipment and/or materials shall be clearly summarized in the preface of each submittal.
- G. The project shall be bid based on the equipment listed in these specifications and on the drawings. After award of the Electrical Contract the Contractor may wish to substitute equipment other than that specified, subject to approval. The Electrical Contractor shall bear the "burden of proof" for demonstrating substitute equipment equivalency and suitability.
- H. The Electrical Contractor shall be required to replace installed "equivalent" equipment if the operation of this equipment does not meet the full design intent of the specified system.
- I. Physical size of equipment used in the design layout are those of reputable equipment manufacturers. The Contractor is responsible for providing equipment which will fit the space provided. If the Contractor elects to use other manufacturer's equipment, any resulting conflicts with space clearance or codes shall be the responsibility of the Contractor to correct at the Contractor's expense.
- J. The Contractor assumes all responsibility for providing code clearances.

## 1.3 COORDINATION OF WORK

- A. It is understood and agreed that the Contractor is, by careful examination, satisfied as to the nature and location of the work, the conformation of the ground, the character, quality and quantity of the materials to be encountered, the general and local conditions and all other matters which can and may affect the work under this

contract. The Contractor shall be held responsible for visiting the site and thoroughly familiarizing himself with the existing conditions and also any contractual requirements as may be set forth in the other Divisions of these Specifications. No extras will be considered because of additional work necessitated by obvious job conditions that are not indicated on the drawings.

- B. The Contractor shall compare the electrical drawings and specifications with the drawings and specifications for other trades, and shall report any discrepancies between them to the Architect/Engineer and obtain written instructions for changes necessary in the electrical work. The electrical work shall be installed in cooperation with other trades installing interrelated work. Before installation, the Contractor shall make proper provisions to avoid interferences in a manner approved by the Architect/Engineer. All changes required in the work of the Contractor caused by neglect to do so shall be made at the expense of the Contractor.
- C. Location of electrical raceways, switches, panels, equipment, fixtures, etc., shall be adjusted to accommodate the work to interferences anticipated and encountered. The Contractor shall determine the exact route and location of each electrical raceway prior to make up and assembly.
  - 1. Right of Way: Lines which pitch shall have the right of way over those which do not pitch. For example, steam, condensate and plumbing drains shall normally have right of way. Lines whose elevations cannot be changed shall have the right of way over lines whose elevations can be changed.
  - 2. Offsets and changes in direction of electrical raceways shall be made as required to maintain proper headroom and to clear pitched lines whether or not indicated on the drawings. The Contractor shall furnish and install elbows, pull boxes, etc., as required to affect these offsets, transitions, and changes in directions. Conflicts between electrical raceways, fixtures, etc., and ductwork or piping which cannot be resolved otherwise, will be resolved by the Architect/Engineer.
- D. Installation and Arrangements: The Contractor shall install all electrical work to permit removal (without damage to other parts) of any equipment requiring periodic replacement or maintenance. The Contractor shall arrange electrical raceways and equipment to permit ready access to valves, cocks, traps, starters, motors, control components, etc., and to clear the opening of swinging and overhead doors and of access panels.

#### 1.4 EQUIPMENT AND MATERIALS (GENERAL)

- A. In compliance with North Carolina General Statute 133.3, the Architect/Engineer has, wherever possible, specified the required performance and design characteristics of all materials utilized in this construction. In some cases it is impossible to specify the required performance and design characteristics and when this occurs the Architect/Engineer has specified three or more examples of equal design or equivalent design, establishing an acceptable range for items of equal or equivalent design. Cited examples are used only to denote the quality standard of product desired and do not restrict bidders to a specific brand, make, manufacturer or specific name and are used only to set forth and convey to bidders the general style, type, character and quality of product desired. Equivalent products will be acceptable.

- B. Substitution of materials, items, or equipment of equal or equivalent design shall be submitted to the Architect/Engineer for approval or disapproval. Equal or equivalent shall be interpreted to mean an item of material or equipment, similar to that named and which is suitable for the same use and capable of performing the same functions as that named, the Architect/Engineer being the judge of equality.
- C. The materials used in all systems shall be new, unused and as hereinafter specified and shall bear the manufacturer's name, trade name and third party testing agency label in every case where a standard has been established for the particular material. Equipment furnished under this specification shall be essentially the standard product of manufacturers regularly engaged in the production of the required type of equipment, and shall be the manufacturer's latest approved design. All materials where not specified shall be of the very best of their respective kinds. Samples of materials or manufacturer's specifications shall be submitted for approval as required by the Architect/Engineer.
- D. Protection: Electrical equipment shall at all times during construction be adequately protected against damage. Equipment shall be tightly covered and protected against dirt, water and chemical or mechanical injury and theft. Electrical equipment shall not be stored out-of-doors. Electrical equipment shall be stored in dry, permanent shelters. If an apparatus has been damaged, such damage shall be repaired at no additional cost. If any apparatus has been subject to possible injury by water, it shall be replaced at no additional cost to the Owner. At the completion of the work, fixtures, equipment, and materials shall be cleaned and polished thoroughly and turned over to the Owner in a condition satisfactory to the Architect/Engineer. Damage or defects, developing before acceptance of the work shall be made good at the Contractor's expense.
- E. Any damage to factory applied paint finish shall be repaired using touch-up paint furnished by the equipment manufacturer. The entire damaged panel or section shall be repainted per the field painting specifications in Division 9, at no additional cost to the Owner.
- F. Where materials such as wiring devices and plates, fire alarm equipment, paging system components, etc. are specified to match existing, provide materials to match existing equipment in finish, color, capacity, ratings, operating characteristics, performance, etc.
- G. Delivery and Storage: Equipment and materials shall be delivered to the site and stored in original containers, suitably sheltered from the elements, but readily accessible for inspection by the Architect/Engineer until installed.
- H. Equipment and materials of the same general type shall be of the same make throughout the work to provide uniform appearance, operation and maintenance.
- I. Manufacturer's directions shall be followed completely in the delivery, storage, protection, and installation of all equipment and materials. The Contractor shall promptly notify the Architect/Engineer, in writing, of any conflicts between any requirements of the Contract Documents and the manufacturer's directions and shall obtain the Architect/Engineer's written instructions before proceeding with the work. Should the Contractor perform any work that does not comply with the manufac-

turer's direction or such written instructions from the Architect/Engineer, the Contractor shall bear all costs arising in correcting the deficiencies.

## 1.5 OPERATION AND MAINTENANCE MANUALS

- A. Submit under relevant sections of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. The Contractor shall provide two compilations of catalog data, bound in suitable loose leaf binders, for each manufactured item of equipment used in the electrical work. These shall be presented to the Architect/Engineer for transmittal to the Owner before the final inspection is made. Data shall include printed installation, operation and maintenance instructions for each item, indexed by product with heavy sheet dividers and tabs. All warranties shall be included with each item. Each manufacturer's name, address and telephone number shall be clearly indicated.
- C. Shop drawings with Architect/Engineer's "as noted" markings are not acceptable for the above. "Approved" shop drawings are acceptable if adequate information is contained therein. Generally, shop drawings alone are not adequate.

## 1.6 PAINTING

- A. All painting will be performed by the General Contractor for the project, unless specifically indicated otherwise.
- B. The Electrical Contractor shall clean all exposed electrical work for painting. Should the Electrical Contractor delay in installing exposed conduit and outlets until the General Contractor has begun painting, the Electrical Contractor shall be required to paint all exposed electrical work at the Electrical Contractor's own expense. Such painting will be accomplished in accordance with the detailed specifications for the Project.
- C. Conductors exposed in boxes and cabinets shall be protected against painting. Devices, cover plates, trims, etc., for panelboards and cabinets shall not be installed until painting has been completed.
- D. The Electrical Contractor shall be responsible for touch up painting that may be required for electrical material or apparatus furnished with factory applied finish.

## 1.7 LOCATIONS AND MEASUREMENTS

Outlets and appliances are shown and located on the drawings as accurately as possible. All measurements shall be verified on the project and in all cases the work shall suit the surrounding trim, finishes and/or construction. The locations of outlets for special appliances shall be installed so that when extended, they are flush with the finished wall or ceiling and permit the proper installation of fixtures and/or devices. Heights of all outlets shown on the drawings are approximate only. Slight relocations of outlets, devices and equipment shall be made by the Contractor as required or as directed by the Architect/Engineer at no additional cost to the Owner.

## 1.8 QUALITY OF WORK

All work shall be executed as required by this specification and the accompanying drawings and shall be done by skilled mechanics, and shall present a neat, trim, and mechanical appearance when completed. All work shall be performed as required by the progress of the job.

## 1.9 SUPERVISION

- A. The Contractor shall personally, or through an authorized and competent representative, constantly supervise the work from the beginning to completion and final acceptance. So far as possible, the Contractor shall keep the same foreman and mechanics throughout the project duration.
- B. During the progress of the work it shall be subject to inspection by representatives of the Architect/Engineer, the Owner, and local inspection authorities, at which time the Contractor shall furnish such required information and data on the project as requested.
- C. The Electrical Contractor shall coordinate the electrical work with other Contractors and cooperate in the preparation and maintenance of a master schedule for the completion of the project.

## 1.10 EXCAVATION, TRENCHING AND BACKFILLING

- A. The Electrical Contractor shall do all excavating, trenching and backfilling in connection with this contract. All such excavation shall be done in a manner as not to endanger or damage existing utility lines and other structures. If damage occurs, the Contractor shall pay for and repair damage to the satisfaction of the Architect/Engineer.
- B. It shall be the responsibility of the Contractor to investigate conditions before excavation and to exercise care during the excavation to avoid any utilities or other objects which may not be shown. Whether or not utilities, etc., are shown on the drawings shall not relieve the Contractor from the responsibility to repair any damage caused by this work. Location of all ditching shall be laid out at grade and shall be approved by the Architect/Engineer before excavating and no work shall be done until such approval has been obtained.
- C. All surplus earth shall be removed by the Contractor from the site and disposed of at the Contractor's expense.
- D. All excavation, trenching and shoring shall be in accordance with rules and regulations set forth in Article XXI, Bulletin 1 "Trenching" as published in a separate bulletin by the North Carolina Department of Labor, Division of Standards and Inspection Construction Bureau.
- E. Backfilling shall be in 6" layers with each layer tamped. No boulders or debris shall be used for backfill material. Where trenching passes through areas designated as

streets, driveways, walkways, or parking areas, backfill shall be tamped with power tamps to 95 percent compaction.

- F. Excavation shall be bid unclassified with no extra payment for removal of rock.

#### 1.11 CLOSING IN WORK

Work shall not be covered up or enclosed until it has been inspected, tested and approved by the authorities having jurisdiction over this work. Should any of the work be enclosed or covered up before such inspection and test, the Contractor shall uncover the work at the Contractor's expense; after it has been inspected, tested and approved, the Contractor shall restore the work to its original condition. The State Electrical Inspector at the State Construction Office shall be call for all inspections at 919-807-4111.

#### 1.12 REFERENCE STANDARDS

- A. All electrical equipment, materials, and installation shall be in accordance with the latest edition of the following codes and standards:
  1. American Association of Edison Illuminating Companies (AEIC)
  2. American National Standards Institute (ANSI)
  3. American Society for Testing and Materials (ASTM)
  4. Building Officials Code Administrators (BOCA)
  5. Energy Code 90.1 (ASHRAE/IES)
  6. Institute of Electrical and Electronic Engineers (IEEE)
  7. Insulated Cable Engineers Association (ICEA)
  8. International Code Council (ICC)
  9. International Conference of Building Officials (ICBO)
  10. National Electrical Code (NEC) 2011 edition
  11. National Electrical Contractor's Association (NECA)
  12. National Electrical Installation Standards (NEIS)
  13. National Electrical Manufacturer's Association (NEMA)
  14. National Electrical Safety Code (NESC)
  15. National Fire Protection Association (NFPA)
  16. North Carolina State Building Code (NCSBC)
  17. North Carolina Construction Manual with GS as listed (NCCM)
  18. North Carolina State Construction Office Electrical Guidelines and Policies, 2011 Edition
  19. Occupational Safety and Health Act (OSHA)
  20. Requirements of the Americans with Disabilities Act (ADA), latest edition.
  21. Underwriters Laboratories Inc (U.L.)
  22. Southern Building Code Congress International (SBCCI)
  23. Toxicity Characteristics Leaching Procedure (TCLP)
  
- B. All electrical equipment and material shall be listed by an approved third party testing agency approved by the NCBCC and shall bear the appropriate testing agency's listing mark or classification marking. Equipment, materials, etc. utilized not bearing a third party testing agency certification shall be field or factory third party testing agency certified prior to equipment acceptance and use.
  
- C. Where reference is made to one of the above standards, the revision in effect at the time of the bid opening shall apply.

### 1.13 ENCLOSURE TYPES

Unless otherwise specified herein or shown on the Drawings, electrical enclosures shall have the following ratings:

1. NEMA 1 for dry, indoor locations.
2. NEMA 3R for outdoor locations, rooms below grade (including basements and buried vaults), "DAMP" and "WET" locations.
3. NEMA 4X for locations subject to corrosion when specifically noted.

### 1.14 CODES, INSPECTION AND FEES

- A. All equipment, materials and installation shall be in accordance with the requirements of the local authority having jurisdiction.
- B. The Electrical Contractor shall obtain all necessary permits and pay all fees required for permits and inspections of electrical work.
- C. The electrical contractor shall notify the State Electrical Inspectors in the State Construction Office to schedule required inspections. No work will be covered up until after inspection has been completed and approved by authorized SCO inspector.

### 1.15 TESTS AND SETTINGS

- A. Test all systems furnished under Division 26 and repair or replace all defective work. Make all necessary adjustments to the systems and instruct the Owner's personnel in the proper operation of the systems.
- B. Make the following minimum tests and checks prior to energizing electrical equipment:
  1. Mechanical inspection, testing and settings of all circuit breakers, disconnect switches, motor starters, control equipment, etc., for proper operation.
  2. Check all wire and cable terminations. Verify to the Architect/Engineer that connections meet the equipment torque requirements.
  3. Check rotation of motors, obtain permission from other contractors to start motor, and proceed to check for proper rotation. If the motor rotates in the wrong direction, correct it. Take all necessary precautions not to damage any equipment.
  4. Provide all instruments and equipment for the tests specified herein.
- C. All testing shall be scheduled and coordinated by the Contractor. Notify the Owner at least two (2) weeks in advance of conducting tests. The Contractor shall have qualified personnel present during all testing.
- D. All tests shall be completely documented with the time of day, date, temperature, and all other pertinent test information. All required documentation of readings indicated shall be submitted to the Architect/Engineer prior to, and as one of the prerequisites for, final acceptance of the project.



- E. **Electrical Distribution System Tests:** All current carrying phase conductors and neutrals shall be tested as installed, and before load connections are made, for insulation resistance and accidental grounds. This shall be done with a 500 volt megger. The following procedures shall be as follows:
1. Minimum readings shall be one million (1,000,000) ohms or more for #6 AWG wire and smaller; 250,000 ohms or more for #4 AWG wire or larger. Measurement to be taken between conductors and between conductor and the grounded metal raceway.
  2. After all fixtures, devices and equipment are installed and all connections completed to each panel, the Contractor shall disconnect the neutral feeder conductor from the neutral bar and take a megger reading between the neutral bar and grounded enclosure. If this reading is less than 250,000 ohms, the Contractor shall disconnect the branch circuit neutral wires from this neutral bar. The Contractor shall then test each one separately to the panel until the low reading ones are found. The Contractor shall correct troubles, reconnect and retest until at least 250,000 ohms from the neutral bar to the grounded panel can be achieved with only the neutral feeder disconnected.
  3. The Contractor shall send a letter to the Architect/Engineer, and to the North Carolina State Construction Office certifying that the above has been done and tabulating the megger readings for each panel. This shall be done at least four (4) days prior to final inspection.
  4. At inspection, the Contractor shall furnish a megger and show Architect/Engineer's representative that the panels comply with the above requirements. The Contractor shall also furnish a clamp type ammeter and a voltmeter and take current and voltage readings as directed by the representatives.
  5. At inspection, the Contractor shall furnish ladders, required tools, and mechanics to open fixtures, boxes, panels, or any other equipment to enable the Architect/Engineer's representatives to see into any parts of the installation that may be requested.
- F. **Electrical Grounding System Tests:** Provide documentation showing values of earth ground impedance for the system ground. See Specifications Section 260526 for testing requirements.

#### 1.16 SLEEVES AND FORMS FOR OPENINGS

- A. Anchor bolts, sleeves, inserts, supports, etc., that may be required for electrical work shall be furnished, located and installed by the Electrical Contractor. The Electrical Contractor shall give sufficient information (marked and located) to the General Contractor in time for proper placement in the construction schedule. Should the Electrical Contractor delay or fail to provide sufficient information in time, then the Electrical Contractor shall cut and patch construction as necessary and required to install electrical work. Such cutting and patching will be done by the General Contractor but paid for by the Electrical Contractor.
- B. Provide and place all sleeves for conduits penetrating floors, walls, partitions, etc. Locate all necessary slots for electrical work and form before concrete is poured.

- C. Where exact locations are required by equipment for stubbing-up and terminating conduit concealed in floor slabs, request shop drawings, equipment location drawings, foundation drawings, and any other data required to locate the concealed conduit before the floor slab is poured.
- D. Where such data is not available in time to avoid delay in scheduled floor slab pours, the Architect/Engineer may elect to allow the installations of such conduits to be exposed. No additional compensation for such change will be allowed and written approval must be obtained from the Architect/Engineer.
- E. Seal all openings, sleeves, penetration, and slots as specified and as shown on the Contract Drawings.

#### 1.17 CUTTING AND PATCHING

- A. For the purposes of the Electrical Contract, "cutting and patching" shall be defined as that work required to introduce new electrical work into existing construction. Work required to install or fit electrical boxes, conduit, enclosures, equipment, etc. into new construction is not "cutting and patching".
- B. The Electrical Contractor shall perform all cutting and patching necessary to install all equipment as required under his contract and shall re-establish all finishes to their original condition where cutting and patching occur.
- C. All cutting and patching shall be done in a thoroughly workmanlike manner.
- D. Core drill holes in existing concrete floors and walls as required.
- E. Install work at such time as to require the minimum amount of cutting and patching.
- F. Do not cut joists, beams, girders, columns or any other structural members without first obtaining written permission from the Architect/Engineer.
- G. Cut opening only large enough to allow easy installation of the conduit.
- H. Patching is to be of the same kind of material as was removed.
- I. The completed patching work shall restore the surface to its original appearance.
- J. Patching of waterproofed surfaces shall render the area of the patching completely waterproofed.
- K. Remove rubble and excess patching materials from the premises.
- L. Raceways and ducts penetrating rated floor, ceiling or wall assemblies shall be properly sealed in accordance with the corresponding Underwriters Laboratories approved method utilizing approved and listed materials.

#### 1.18 INTERPRETATION OF DRAWINGS

- A. The Electrical drawings and specifications are complementary each to the other and what may be called for by one shall be as binding as if called for by both. The

drawings are diagrammatic and indicate generally the location of outlets, devices, equipment, wiring, etc. Drawings shall be followed as closely as possible; however, all work shall suit the finished surroundings and/or trim.

- B. Do not scale electrical drawings. Refer to the architectural drawings for dimensions.
- C. Where the words "furnish and install" or "provide" are used, it is intended that this contractor shall purchase and install completely any and/or all material necessary and required for this particular item, system, equipment, etc.
- D. Where the words "the Contractor" or "this Contractor" appear in either the Electrical Drawings or Division 26 Specifications, it shall mean the Electrical Contractor.
- E. Any omission from either the drawings or these specifications are unintentional, and it shall be the responsibility of this Contractor to call to the attention of the Architect/Engineer any pertinent omissions before submitting a bid. Complete and working systems are required, whether every small item of material is shown and specified or not.
- F. Where no specific material or equipment type is mentioned, a high quality product of a reputable manufacturer may be used provided it conforms to the requirements of these specifications. These materials shall be listed or labeled by a Third Party Testing Agency accredited by the NCBCCC to label electrical equipment.
- G. The electrical drawings show the general arrangement of raceways, equipment, fixtures, and appurtenances and shall be followed as closely as actual building construction and the work of other trades will permit. Some adjustment of routings and installation of conduit, cable tray and devices should be expected. The electrical work shall conform to the requirements shown on all of the drawings. General and Structural drawings shall take precedence over Electrical Drawings. Because of small scale of the electrical drawings, it is not possible to indicate offsets, fittings and accessories which may be required. The Contractor shall investigate the structural and finish conditions affecting the work and shall arrange his work accordingly, providing such fittings and accessories as may be required to meet such conditions, without additional cost to the Owner and as directed by the Architect/Engineer.
- H. Each 3-phase circuit shall be run in a separate conduit unless otherwise shown on the Drawings.
- I. Unless otherwise approved by the Architect/Engineer, conduit shown exposed shall be installed exposed; conduit shown concealed shall be installed concealed.
- J. Where circuits are shown as "home runs" all necessary fittings and boxes shall be provided for a complete raceway installation.
- K. Verify with the Architect/Engineer the exact locations and mounting heights of lighting fixtures, switches and receptacles prior to installation.

- L. Any work installed contrary to or without approval by the Architect/Engineer shall be subject to change as directed by the Architect/Engineer, and no extra compensation will be allowed for making these changes.
- M. The locations of equipment, fixtures, outlets, and similar devices shown on the Drawings are approximate only. Exact locations shall be as approved by the Architect/Engineer during construction. Obtain in the field all information relevant to the placing of electrical work and in case of any interference with other work, proceed as directed by the Architect/Engineer and furnish all labor and materials necessary to complete the work in an approved manner.
- N. Surface mounted panel boxes, junction boxes, conduit, etc., shall be supported by spacers to provide a clearance between wall and equipment.
- O. Circuit layouts are not intended to show the number of fittings, or other installation details. Furnish all labor and materials necessary to install and place in satisfactory operation all power, lighting, and other electrical systems shown. Additional circuits shall be installed wherever needed to conform to the specific requirements of equipment.
- P. All connections to the equipment shall be made as required, and in accordance with the approved shop and setting drawings.
- Q. Redesign of electrical work, which is required due to the Contractor's use of an alternate item, arrangement of equipment and/or layout other than specified herein, shall be done by the Contractor at the Contractor's expense. Redesign and detailed plans shall be submitted to the Architect/Engineer for approval. No additional compensation will be provided for changes in the work, either the Electrical Contractor's or others, caused by such redesign.
- R. All floor mounted electrical equipment shall be placed on 4-inch thick concrete housekeeping pads. Edges shall be chamfered.

#### 1.19 SIZE OF EQUIPMENT

- A. Investigate each space in the structure through which equipment must pass to reach its final location. If necessary, the manufacturer shall be required to ship his materials in sections sized to permit passing through such restricted areas in the structure.
- B. The equipment shall be kept upright at all times. When equipment has to be tilted for ease of passage through restricted areas during transportation, the manufacturer shall be required to suitably brace the equipment, to insure that the tilting does not impair the functional integrity of the equipment.

#### 1.20 EXISTING BUILDINGS AND CONSTRUCTION

- A. The Contractor is cautioned that some of the work to be performed under this contract is to be accomplished in an existing occupied building. All such work shall be scheduled and arranged to be done at the convenience of the Owner so as not to interfere with, disrupt, or disturb normal operations in the building. The Contractor

shall obtain approval from the Owner before proceeding with work in existing buildings and shall work in existing buildings on schedule as agreed upon with the Owner. This is not to be necessarily construed to mean that the Contractor is expected to perform work on buildings on holidays, weekends, etc., but that the Contractor must schedule work with the Owner for the Owner's beneficial and normal usage of the buildings, and that the Contractor will be required to maintain the schedule as approved by the Owner.

- B. The Contractor shall, at all times, provide safety barriers, protective devices, screening, dust barriers, etc., as required to maintain the safety and comfort of the building's personnel and/or occupants in or near the work area.
- C. The Contractor shall be responsible for cleanup in connection with work in existing buildings. At the end of each working day, all debris, boxes, waste, etc., shall be removed from the buildings and properly disposed of. Equipment, materials, etc., may be left inside the buildings, but such must be properly stored, stacked and located as approved by the Owner.
- D. The Contractor shall do all cutting, patching, finishing, repairing, painting, etc., necessary for electrical work to be installed in existing buildings. All finishes shall be left to equal finish and condition prior to cutting. No cutting of structural members will be allowed. All cutting of walls, floors, roofs, etc., shall be repaired and/or replaced to equal finish prior to cutting. The Contractor shall route conduits and locate equipment as approved by the Owner and Architect/Engineer. Routings and locations shall be firmly established and approved before proceeding with any phase of the work.
- E. The Contractor shall be responsible for any and all damage to the existing buildings, grounds, walkways, paving, etc., caused by the work, the Contractor and/or Contractor's personnel, and/or Contractor's equipment in the accomplishment of this work. Such damages shall be repaired and/or replaced by the Contractor at no additional cost to the Owner, to finish equal to that finish prior to damage. The Architect/Engineer shall be the judge as to equal finishes, etc.

#### 1.21 RECORD DRAWINGS

- A. As the work progresses, legibly record all field changes on one set of project contract drawings, herein after called the "record drawings".
- B. Record drawings shall accurately show the installed condition of the following items:
  - 1. Panel schedule(s).
  - 2. Lighting fixture schedule(s).
  - 3. Branch circuit conduit and conductor sizes.
  - 4. Lighting fixture, receptacle, and switch outlets, interconnections and homeruns with circuit identification.
  - 5. Underground raceway routing.
  - 6. Telecommunications system.

#### 1.22 CORROSION PROTECTION

All equipment, raceways, hardware, etc., furnished under the electrical contract shall be protected from corrosion by factory applied coatings, paint and galvanizing, or shall be fabricated of high quality 300 series stainless steel. All exposed hardware shall be hot dip galvanized. The requirements of preceding section entitled "Delivery and Storage" shall be strictly followed. Touch up any scratched metallic surfaces immediately to prevent corrosion. Apply cold galvanizing compound to all galvanized surfaces damaged during installation, i.e., cutting, etc. Rusted or corroded materials shall be replaced before final acceptance of the work.

#### 1.23 GUARANTEE

The Contractor shall guarantee the materials and workmanship covered by these drawings and specifications for a period of one year from the date of acceptance by the Owner. The Contractor shall repair and/or replace any parts of any system that may prove to be defective at no additional cost to the Owner within the guarantee period. All equipment warranties shall be as specified and included in the Contract Documents.

#### 1.24 PHASING OF THE WORK

The Electrical Contractor shall schedule his work as described in the relevant sections of the General and Supplemental General Conditions and Division 1 Specifications Sections.

#### 1.25 ALTERNATE BIDS

Alternate bid items are described in relevant sections of the General and Supplemental General Conditions and Division 1 Specifications Sections.

PART 2 PRODUCTS Not used.

PART 3 EXECUTION Not used.

END OF SECTION

## **SECTION 260510 - SELECTIVE ELECTRICAL DEMOLITION**

### **PART 1 GENERAL**

#### **1.1 SECTION INCLUDES**

Selective electrical demolition shall be provided by the Electrical Contractor as described herein and as shown on the contract drawings. Gross demolition will be provided by the General Contractor. Identify active utilities, and at the appropriate time, disconnect and cap off such utilities and provide experienced personnel on site during General Contractor demolition operations to perform such operations and resolve issues. Remove materials noted for salvage and reuse.

#### **1.2 RELATED SECTIONS**

Division 2 - Demolition

### **PART 2 PRODUCTS**

#### **2.1 MATERIALS AND EQUIPMENT**

Materials and equipment for patching and extending work: As specified in individual Sections.

### **PART 3 EXECUTION**

#### **3.1 EXAMINATION**

- A. Verify field measurements and circuiting arrangements are as shown on Drawings.
- B. Verify that abandoned wiring and equipment serve only abandoned facilities.
- C. Demolition Drawings are based on limited field observation and existing record documents. Survey the affected areas before submitting bid proposal. Report discrepancies to the Architect/Engineer before disturbing the existing installation.
- D. Beginning of demolition means the Contractor accepts existing conditions.

#### **3.2 PREPARATION**

- A. Disconnect and/or de-energize electrical systems in walls, floors, and ceilings scheduled for removal.
- B. Coordinate power outages with the Owner.
- C. Provide temporary and/or permanent wiring and connections as shown and/or as required by conditions to maintain existing systems in service during construction. When work must be performed on energized equipment or circuits, and when such

work is specifically approved by the Owner, use personnel experienced in such operations.

- D. Existing Electrical Service: Maintain existing systems in service. Disable systems only to make switchovers and connections. Obtain permission from the Owner at least 24 hours before partially or completely disabling system. Minimize outage duration. Make temporary connections to maintain service in areas adjacent to work area.

### 3.3 DEMOLITION AND EXTENSION OF EXISTING ELECTRICAL WORK

- A. Demolish and extend existing electrical work under provisions of relevant sections of the General and Supplemental General Conditions, Division 1 Specifications Sections, Section 260000 and this Section.
- B. Identify and mark wiring to remain for the General Contractor.
- C. Remove materials designated for salvage and reuse.
- D. Remove, relocate, and extend existing installations to accommodate new construction.
- E. Remove disconnected and abandoned wiring to source of supply.
- F. Remove electrical work associated with equipment scheduled for demolition except those portions indicated to remain or be reused. Remove unused/abandoned exposed conduit and wiring, including abandoned conduit above accessible ceiling finishes, back to point of concealment. Remove unused/abandoned wiring in concealed conduits back to source (or nearest point of usage). Cut conduit flush with walls and floors, and patch surfaces.
- G. Remove exposed wireways, outlet boxes, pull boxes, and hangers made obsolete by the alterations, unless specifically designated to remain.
- H. Where electrical systems pass through the demolition areas to serve other portions of the premises, they shall remain or be suitably relocated and the system restored to normal operation. Coordinate outages in systems with the Owner. Where duration of proposed outage cannot be allowed by the Owner, provide temporary connections as required to maintain service.
- I. Repair adjacent construction and finishes damaged during electrical demolition and extension work.
- J. Disconnect and remove abandoned luminaires. Remove brackets, stems, hangers, and other accessories.
- K. Disconnect and remove electrical devices serving utilization equipment that has been removed.



- L. Disconnect abandoned outlets and remove devices. Remove abandoned outlets if conduit servicing them is abandoned and removed. Provide blank cover for abandoned outlets which are not removed.
- M. Maintain access to existing electrical installations which remain active. Modify installation or provide access panel as appropriate.
- N. Continuous service is required on all circuits and outlets affected by these changes, except where the Owner will permit an outage for a specific time. Obtain Owner's consent before removing any circuit from continuous service.
- O. Extend existing installations using materials and methods compatible with existing electrical installations, or as specified.

#### 3.4 DISPOSAL, CLEANING AND REPAIR

In general, it is intended that material and equipment indicated to be removed and disposed of by the Electrical Contractor shall, upon removal, become the Contractor's property and shall be disposed of, off the site, by the Contractor unless otherwise directed by the Owner. A receipt showing acceptable disposal of any legally regulated materials or equipment shall be given to the Owner.

- A. Clean and repair existing materials and equipment which remain or are to be reused.
- B. Panelboards: Clean exposed surfaces and check tightness. Provide new typed circuit directories showing revised circuiting arrangement.
- C. Luminaires: When specifically noted, remove existing luminaires for cleaning. Use mild detergent to clean all exterior and interior surfaces; rinse with clean water and wipe dry. Replace lamps, ballasts, and broken electrical parts.
- D. All salvageable materials shall be properly stored by the Electrical Contractor until installed in new construction.

#### 3.5 INSTALLATION

Install relocated materials and equipment under the provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.

END OF SECTION

## **SECTION 260519 - BUILDING WIRE AND CABLE**

### **PART 1 GENERAL**

#### **1.1 SECTION INCLUDES**

- A. Building wire and cable.
- B. Wiring connectors and connections.

#### **1.2 RELATED SECTIONS**

- A. Section 260533 - Conduit.
- B. Section 260534 - Boxes.
- C. Section 260553 - Identification.

#### **1.3 REFERENCES**

- A. ANSI/NFPA 70 - National Electrical Code.
- B. NECA Standard of Installation (National Electrical Contractors Association).

#### **1.4 SUBMITTALS**

- A. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Product Data: Provide manufacturer's catalog information showing dimensions, ratings, colors, and configurations.
- C. Test Reports: Indicate procedures and values obtained.
- D. Manufacturer's Installation Instructions: Indicate application conditions and limitations of use stipulated by product testing agency specified under Regulatory Requirements.

#### **1.5 QUALIFICATIONS**

- A. Manufacturer: Company specializing in manufacturing products specified in this Section with minimum three years documented experience.

#### **1.6 REGULATORY REQUIREMENTS**

- A. Conform to requirements of ANSI/NFPA 70.
- B. Furnish products listed and classified by testing firm acceptable to authority having jurisdiction as suitable for purpose specified and shown.

#### **1.7 PROJECT CONDITIONS**

- A. All wire and cable shall be installed in conduit. This includes all power wiring; fire alarm, sound and communications wire and cable (unless noted otherwise); HVAC control cable; etc.
- B. Verify that field measurements are as shown on Drawings.
- C. Conductor sizes are based on 75° C. copper.
- D. Wire and cable routing shown on Drawings is approximate unless dimensioned. Route wire and cable as required to meet Project Conditions.
- E. Where wire and cable routing is not shown, and destination only is indicated, determine exact routing and lengths required.

## 1.8 COORDINATION

- A. Coordinate Work under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.

## PART 2 PRODUCTS

### 2.1 BUILDING WIRE AND CABLE

- A. Description: Single conductor insulated building wire.
- B. Conductor: Copper. Solid and stranded as specified below. Minimum #12 AWG, maximum 500 KCMil.
- C. Insulation/Voltage Rating: 600 volts.
- D. Insulation: Dual-rated THHN/THWN or XHHW.
- E. Color Coding:
 

	<u>120/240 volts and 208/120 volts</u>	<u>480/277 volts</u>
Phase A -	Black	Brown
Phase B -	Red	Orange
Phase C -	Blue	Yellow
Neutral -	White	Gray
Ground -	Green	Green

### 2.2 WIRING CONNECTORS AND CONNECTIONS

- A. Conductors shall be installed continuous from outlet to outlet with no splicing except within outlet or junction boxes, troughs and gutters. Make splices, taps, and terminations to carry full ampacity of conductors with no perceptible temperature rise.
- B. Use mechanical connectors for copper conductor splices and taps, 8 AWG and larger, except main grounding conductors, which shall be terminated with compression lugs. Tape un-insulated conductors and connector with electrical

tape to 150 percent of insulation rating of conductor or use third party testing agency-approved insulating covers.

- C. Use insulated spring wire connectors with plastic caps for copper conductors, 10 AWG and smaller, splices and taps in junction boxes, outlet boxes and lighting fixtures, Ideal "wirenuts", 3M Company "Scotchlock" or [T&B "Piggy"] connectors in. "Push wire" type connectors are not acceptable. [remove piggy for SCO projects]
- D. "Sta-Kon" or other permanent type crimp connectors shall not be used for branch circuit connections.
- E. Joints in stranded conductors shall be spliced by approved mechanical connectors and gum rubber tape or friction tape. Solderless mechanical connectors for splices and taps, provided with U.L approved insulating covers, may be used instead of mechanical connectors plus tape.

## PART 3 EXECUTION

### 3.1 EXAMINATION

- A. Verify that interior of building has been protected from weather.
- B. Verify that mechanical work likely to damage wire has been completed.
- C. Verify that raceway installation is complete and supported.

### 3.2 PREPARATION

- A. Completely and thoroughly swab raceway before installing wire.

### 3.3 WIRING METHODS

- A. Concealed Dry Interior Locations: Use only building wire in raceway.
- B. Exposed Dry Interior Locations: Use only building wire in raceway.
- C. Above Accessible Ceilings: Use only building wire in raceway.
- D. Wet or Damp Interior Locations: Use only building wire in raceway.
- E. Exterior Locations: Use only building wire in raceway.
- F. Underground Installations: Use only building wire in raceway.

### 3.4 INSTALLATION

- A. Install products in accordance with manufacturers instructions.

- B. Route wire and cable as required to meet Project Conditions.
- C. Install cable in accordance with the NECA "Standard of Installation".
- D. Use solid conductor for feeders and branch circuits 10 AWG and smaller, and Class B stranded for larger conductors.
- E. Use conductor not smaller than 12 AWG for power and lighting circuits.
- F. Use conductor not smaller than 14 AWG for fire alarm and control circuits.
- G. Use 10 AWG conductors for 20 ampere, 120 volt branch circuits longer than 75 feet (23 m) or branch circuit homeruns longer than 50 feet.
- H. Use 10 AWG conductors for 20 ampere, 277 volt branch circuits longer than 200 feet or branch circuit homeruns longer than 125 feet.
- I. Pull all conductors into raceway at same time.
- J. Use suitable wire pulling lubricant for building wire 4 AWG and larger.
- K. Neatly train and lace wiring inside boxes, equipment, and panelboards.
- L. Clean conductor surfaces before installing lugs and connectors.
- M. Identify wire and cable under provisions of Section 260553.
- N. Identify each conductor with its circuit number or other designation indicated on Drawings.
- O. Common neutral multiwire receptacle branch circuits are not permitted. Provide separate, individual neutral conductors for receptacle circuits.

### 3.5 FIELD QUALITY CONTROL

- A. Perform field inspection and testing under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Inspect wire for physical damage and proper connection.
- C. Measure tightness of bolted connections and compare torque measurements with manufacturer's recommended values.
- D. Verify continuity of each branch circuit conductor.
- E. Prior to energizing, feeders, sub-feeders and service conductor cables shall be tested for electrical continuity and short circuits. A copy of these tests shall be sent to the North Carolina State Construction Office through the Architect.

END OF SECTION

## **SECTION 260526 - GROUNDING AND BONDING**

### **PART 1 GENERAL**

#### **1.1 SECTION INCLUDES**

- A. Equipment grounding conductors.

#### **1.2 REFERENCES**

- A. IEEE 142 - Recommended Practice for Grounding of Industrial and Commercial Power Systems.
- B. NFPA 70 - National Electrical Code.

#### **1.3 SUBMITTALS FOR REVIEW**

- A. Submittals: Procedures for submittals. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Product Data: Provide for grounding electrodes and connections.

#### **1.4 SUBMITTALS FOR INFORMATION**

- A. Submittals: Submittals for information. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Test Reports: Indicates overall resistance to ground and resistance of each electrode.
- C. Manufacturer's Instructions: Indicate application conditions and limitations of use stipulated by Product testing agency specified under Regulatory Requirements. Include instructions for storage, handling, protection, examination, preparation, and installation of Product.

#### **1.5 SUBMITTALS FOR CLOSEOUT**

- A. Contract Closeout: Procedures for submittals as required under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Project Record Documents: Record actual locations of components and grounding electrodes.
- C. Certificate of Compliance: Indicate approval of installation by authority having jurisdiction.

## 1.6 QUALIFICATIONS

Manufacturer: Company specializing in manufacturing the Products specified in this section with minimum three years documented experience, and with service facilities within 100 miles of Project.

## 1.7 REGULATORY REQUIREMENTS

- A. Conform to requirements of NFPA 70.
- B. Products: Listed and classified by testing firm acceptable to the authority having jurisdiction as suitable for the purpose specified and indicated.

## PART 2 PRODUCTS

### 2.1 WIRE

- A. Material: Copper. Use solid conductor for 10 AWG and smaller, and Class B stranded for larger conductors, all sized per NEC requirements.

## PART 3 EXECUTION

### 3.1 EXAMINATION

Coordination and Meetings: Verify existing conditions prior to beginning work as required under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.

### 3.2 INSTALLATION

- A. Quality Control: Manufacturer's instructions shall be followed as required under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Provide bonding to meet Regulatory Requirements.
- C. Provide separate, insulated conductor within each feeder and branch circuit raceway.
- D. Equipment Grounding Conductor: The raceway system shall not be relied on for ground continuity. A green grounding conductor, properly sized per the NEC (Table 250-122) shall be run in all raceways. Terminate each end on suitable lug, bus, or bushing. Exceptions are as follows:
  - 1. Raceways for telecommunications.
  - 2. Raceways for data.
  - 3. Raceways for audio conductors.
  - 4. Services.
- E. Equipment grounding continuity shall be maintained through flexible conduit as required in previous sections.

- F. Grounding conductors shall be installed as to permit the shortest and most direct path from equipment to ground. All connections to ground conductors shall be accessible for inspection and made with approved solderless connectors, brazed or bolted to the equipment or structure to be grounded. All contact surfaces shall be thoroughly cleaned before connections are made to insure good metal to metal contact.
- G. All equipment housings and/or enclosures, and all non-current carrying metallic parts of electrical equipment, raceway systems, etc., shall be effectively and adequately bonded to ground.
- H. Grounding type insulated bonding bushings and jumpers shall be provided where concentric, eccentric or over-sized knockouts are encountered. The jumpers shall be sized per NEC Table 250-66 for services and transformers, and per Table 250-122 for branch circuits.
- I. All metallic raceways entering or leaving panelboards (branch circuits less than 30 amperes in lighting and appliance branch circuit panelboards excepted), switchboards, transfer switches, enclosed circuit breakers, safety switches, transformers, etc. shall be provided with insulated grounding and bonding bushings and each separate piece of raceway shall be individually bonded to the equipment ground bus or metallic enclosure, as applicable, by means of copper conductor sized in accordance with the National Electrical Code, Tables 250-66 for services and transformers and 250-122 for other circuits.
- J. All wiring devices equipped with grounding connections shall be permanently and securely connected to the enclosure in which they are mounted with a copper grounding jumper.
- K. The frame of all lighting fixtures shall be securely grounded to the equipment ground system with grounding conductors.

### 3.3 FIELD QUALITY CONTROL

- A. Quality Assurance: Field inspection, testing and adjusting as required under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.

END OF SECTION



## **SECTION 260529 - SUPPORTING DEVICES**

### **PART 1 GENERAL**

#### **1.1 SECTION INCLUDES**

- A. Conduit and equipment supports.
- B. Anchors and fasteners.

#### **1.2 REFERENCES**

- A. NECA - National Electrical Contractors Association.
- B. ANSI/NFPA 70 - National Electrical Code.

#### **1.3 SUBMITTALS**

- A. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Product Data: Provide manufacturer's catalog data for fastening systems.
- C. Manufacturer's Instructions: Indicate application conditions and limitations of use stipulated by Product testing agency specified under Regulatory Requirements. Include instructions for storage, handling, protection, examination, preparation, installation, and starting of Product.

#### **1.4 REGULATORY REQUIREMENTS**

- A. Conform to requirements of ANSI/NFPA 70.
- B. Furnish products listed and classified by testing firm acceptable to authority having jurisdiction as suitable for purpose specified and shown.

### **PART 2 PRODUCTS**

#### **2.1 PRODUCT REQUIREMENTS**

- A. Materials and Finishes: Provide adequate corrosion resistance.
- B. Provide materials, sizes, and types of anchors, fasteners and supports to carry the loads of equipment and conduit. Consider weight of wire in conduit when selecting products.
- C. Anchors and Fasteners:
  - 1. Concrete Structural Elements: Use expansion anchors.
  - 2. Steel Structural Elements: Use beam clamps.
  - 3. Concrete Surfaces: Use self-drilling anchors and expansion anchors.
  - 4. Hollow Masonry, Plaster, and Gypsum Board Partitions: Use toggle bolts.

5. Solid Masonry Walls: Use expansion anchors.
6. Sheet Metal: Use sheet metal screws or bolts
7. Wood Elements: Use wood screws.

## PART 3 EXECUTION

### 3.1 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.
- B. Provide anchors, fasteners, and supports in accordance with NECA "Standard of Installation".
- C. Do not fasten supports to pipes, ducts, mechanical equipment, and conduit.
- D. Do not use powder-actuated anchors.
- E. Obtain permission from Architect/Engineer before drilling or cutting structural members.
- F. Fabricate supports from structural steel or steel channel. Rigidly weld members or use hexagon head bolts to present neat appearance with adequate strength and rigidity. Use spring lock washers under all nuts.
- G. Install surface-mounted cabinets and panelboards with minimum of four anchors.
- H. In wet and damp locations use steel channel supports to stand cabinets and panelboards one inch (25 mm) off wall.
- I. Conduits installed on the interior of exterior building walls shall be spaced away from the wall surface a minimum of 1/4 inch (65mm) using "clamp-backs" or struts.
- J. Use sheet metal channel to bridge studs above and below cabinets and panelboards recessed in hollow partitions.

END OF SECTION

## **SECTION 260533 - CONDUIT**

### **PART 1 GENERAL**

#### **1.1 SECTION INCLUDES**

- A. Metal conduit.
- B. Flexible metal conduit.
- C. Liquidtight flexible metal conduit.
- D. Electrical metallic tubing.
- E. Nonmetallic conduit.

#### **1.2 RELATED SECTIONS**

- A. Division 7: Fire Stopping.
- B. Division 7: Roofing penetrations.
- C. Section 260534 - Boxes.
- D. Section 260526 - Grounding and Bonding.
- E. Section 260529 - Supporting Devices.
- F. Section 260553 - Electrical Identification.

#### **1.3 REFERENCES**

- A. ANSI C80.1 - Rigid Steel Conduit, Zinc Coated.
- B. ANSI C80.3 - Electrical Metallic Tubing, Zinc Coated.
- C. ANSI/NEMA FB 1 - Fittings, Cast Metal Boxes, and Conduit Bodies for Conduit and Cable Assemblies.
- D. ANSI/NFPA 70 - National Electrical Code.
- E. NECA "Standard of Installation".
- F. NEMA TC2 - Schedule 40 PVC
- G. NEMA TC 3 - PVC Fittings for Use with Rigid PVC Conduit and Tubing.

#### **1.4 DESIGN REQUIREMENTS**

Conduit Size: ANSI/NFPA 70.

## 1.5 SUBMITTALS

- A. Submit under provisions of relevant sections of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Product Data: Provide for metallic conduit, flexible metal conduit, liquidtight flexible metal conduit, metallic tubing, nonmetallic conduit, fittings and conduit bodies.

## 1.6 PROJECT RECORD DOCUMENTS

- A. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Accurately record actual routing of conduits larger than 2 inches (51 mm).

## 1.7 REGULATORY REQUIREMENTS

- A. Conform to requirements of ANSI/NFPA 70.
- B. Furnish products listed and classified by testing firm acceptable to authority having jurisdiction as suitable for purpose specified and shown.

## 1.8 DELIVERY, STORAGE, AND HANDLING

- A. Deliver, store, protect, and handle Products to site under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Accept conduit on site. Inspect for damage.
- C. Protect conduit from corrosion and entrance of debris by storing above grade. Provide appropriate covering.
- D. Protect PVC conduit from sunlight.

## 1.9 PROJECT CONDITIONS

- A. Verify that field measurements are as shown on Drawings.
- B. Verify routing and termination locations of conduit prior to rough-in.
- C. Conduit routing is shown on Drawings in approximate locations unless dimensioned. Route as required to complete wiring system.

## PART 2 PRODUCTS

### 2.1 CONDUIT REQUIREMENTS

- A. Size: Conduit shall be sized in accordance with the latest edition of the NEC unless shown otherwise, with minimum conduit size being ½ inch, except

homeruns minimum size shall be 3/4". Flexible metal and watertight ("sealtite") conduit in size 1/2 inch and larger are acceptable for motor, appliance and fixture connections provided green ground wire is installed (see Section 260526) and NEC is followed.

- B. Underground Installations:
  - 1. More than Five Feet from Foundation Wall: Use rigid steel conduit, intermediate metal conduit, plastic coated conduit, thickwall nonmetallic conduit and thinwall nonmetallic conduit.
  - 2. Within Five Feet from Foundation Wall: Use rigid steel conduit.
  - 3. In or Under Slab on Grade: Use rigid steel conduit, intermediate metal conduit, plastic coated conduit, thickwall nonmetallic conduit and thinwall nonmetallic conduit.
  - 4. Minimum Size: 1 inch (25 mm).
- C. Outdoor Locations, Above Grade: Use rigid steel conduit.
- D. In Slab Above Grade:
  - 1. Use rigid steel conduit.
  - 2. Maximum Size Conduit in Slab: 3/4 inch (19 mm).
- E. Wet and Damp Locations: Use rigid steel conduit.
- F. Dry Locations:
  - 1. Concealed: Use rigid steel conduit, intermediate metal conduit or electrical metallic tubing. EMT may be utilized as permitted by the NEC, with the following restrictions. EMT shall not be installed:
    - a. where tubing, couplings, elbows and fittings would be in direct contact with the earth.
    - b. underground (in/below slab-on-grade or in earth).
    - c. any location outdoors where the tubing, etc., would be subjected to the elements.
    - d. where subject to severe corrosive influence.
    - e. where subject to severe physical damage.
  - 2. Exposed: Use rigid steel conduit or intermediate metal conduit.

## 2.2 METAL CONDUIT

- A. Rigid Steel Conduit: ANSI C80.1.
- B. Plastic-Coated Rigid Steel Conduit: ANSI C80.1, 40 mil PVC coating.
- C. Intermediate Metal Conduit (IMC): Rigid steel.
- D. Fittings and Conduit Bodies: ANSI/NEMA FB 1; material to match conduit with all steel fittings.

## 2.3 FLEXIBLE METAL CONDUIT

- A. Description: Interlocked steel construction.

B. Fittings: ANSI/NEMA FB 1, steel.

## 2.4 LIQUIDTIGHT FLEXIBLE METAL CONDUIT

A. Description: Interlocked steel construction with PVC jacket.

B. Fittings: ANSI/NEMA FB 1, steel or nonmetallic type.

## 2.5 ELECTRICAL METALLIC TUBING (EMT)

A. Description: ANSI C80.3; galvanized tubing.

B. Fittings and Conduit Bodies: ANSI/NEMA FB 1; steel or malleable iron, compression type, insulated throat.

## 2.6 NONMETALLIC CONDUIT

A. Description: NEMA TC 2; Schedule 40 PVC.

B. Fittings and Conduit Bodies: NEMA TC 3.

## PART 3 EXECUTION

### 3.1 INSTALLATION

A. Circuiting is shown schematically. Exact routing of branch circuits may be varied to suit building construction; however, the combination of circuits within raceways and panelboard connections shall not be changed from those shown on the drawings.

B. Raceways shall be installed concealed in finished areas. Where construction does not permit concealed raceways and where indicated on the drawings, raceways shall be run exposed. Exposed raceways shall be run parallel to, or at a right angle with the building walls. Route conduit installed above accessible ceilings parallel and perpendicular to walls.

C. Where any run of rigid conduit may change to a run of EMT or vice-versa, each change shall be made in a junction or outlet box with each conduit terminated separately therein. Rigid conduit to EMT (or vice-versa) adapters shall not be permitted.

D. Install conduit in accordance with NECA "Standard of Installation".

E. Arrange conduit to maintain headroom and present neat appearance.

F. Maintain adequate clearance between conduit and piping.

G. Maintain 12 inch (300 mm) clearance between conduit and surfaces with temperatures exceeding 104 degrees F (40 degrees C).

H. Cut conduit square using saw or pipecutter and de-burr cut ends.

- I. Bring conduit to shoulder of fittings; fasten securely.
- J. Use conduit hubs or sealing locknuts to fasten conduit to sheet metal boxes in damp and wet locations and to cast boxes.
- K. Install no more than equivalent of three 90-degree bends between boxes. Use conduit bodies to make sharp changes in direction, as around beams. Use factory elbows, or hydraulic one-shot bender, to fabricate bends in metal conduit larger than 2 inch size.
- L. Avoid moisture traps; provide junction box with drain fitting at low points in conduit system.
- M. Provide suitable fittings to accommodate expansion and deflection where conduit crosses, control and expansion joints.
- N. Provide suitable pull string in each empty conduit except sleeves and nipples.
- O. Use suitable caps to protect installed conduit against entrance of dirt and moisture.
- P. The raceway system shall not be relied on for grounding continuity. Ground and bond conduit under provisions of Section 260526.
- Q. Identify conduit under provisions of Section 260553.
- R. The use of "LB's" shall be limited where possible. Where necessary to use "LB's" sized above 2 inch, mogul units shall be installed.
- S. Where concentric, eccentric or over-sized knockouts are encountered, a grounding type insulated bushing shall be provided.
- T. Fasten conduit supports to building structure and surfaces under provisions of Section 260529.
- U. Arrange supports to prevent misalignment during wiring installation.
- V. Support conduit using coated steel or malleable iron straps, lay-in adjustable hangers, clevis hangers, and split hangers.
- W. Group related conduits; support using conduit rack. Construct rack using steel channel; provide space on each for 25 percent additional conduits.
- X. Do not support conduit with wire or perforated pipe straps. Remove wire used for temporary supports.
- Y. Do not attach conduit to ceiling support wires.
- Z. All metallic raceways entering or leaving panelboards (branch circuits less than 30 amperes in lighting and appliance branch circuit panelboards excepted), switchboards, transfer switches, enclosed circuit breakers, safety switches,

transformers, etc. shall be provided with insulated grounding and bonding bushings and each separate piece of raceway shall be individually bonded to the equipment ground bus or metallic enclosure, as applicable, by means of copper conductor sized in accordance with the National Electrical Code.

- AA. The term "fittings" includes couplings, connectors, offsets, LBs, etc.
- BB. No pressure cast (pot metal) fittings or conduit bodies shall be allowed.
- CC. Outlets, junction, taps, etc., on exposed rigid metal conduit shall be cast metal conduit fittings or cast metal boxes of the type and size appropriate for the location. Sheet steel outlet boxes shall not be permitted on exposed raceway runs except at or near a ceiling for interior construction.
- DD. EMT couplings and terminations shall be made utilizing steel-plated hexagonal compression connectors. No set screw or indented type fittings shall be utilized.
- EE. EMT couplings and terminations shall be "concrete tight" where buried in masonry or concrete. EMT fittings, where installed in damp locations, shall be of the "raintight" type.
- FF. Install nonmetallic conduit in accordance with manufacturer's instructions.
- GG. Join nonmetallic conduit using cement as recommended by manufacturer. Wipe nonmetallic conduit dry and clean before joining. Apply full even coat of cement to entire area inserted in fitting. Allow joint to cure for 20 minutes, minimum.
- HH. PVC schedule 40 shall not be used exposed or concealed in gypsum walls, but may be used in CMU walls.
- II. IMC and GRC shall terminate with either a double locknut / bushing set, or in a threaded hub.
- JJ. Conduit couplings for IMC, GRC and PVC shall be in accordance with the NEC.
- KK. The placement of conduit in floor slabs shall be thoroughly coordinated with the General Contractor to avoid conflicts with steel reinforcing bars, reductions in net concrete sections and floor penetrations.
- LL. Route conduit in and under slab from point-to-point.
- MM. Do not cross conduits in slab.
- NN. Schedule 40 PVC may be used in elevated floor slabs and in foundation slabs. Minimum concrete cover shall be 3/4 inch at finished or formed surface and shall be 3 inches at concrete surface cast against earth or for slabs placed on-grade. Greater amounts of concrete cover shall be used in areas subject to damage.
- OO. Where underground or underslab raceways are required to turn up into cabinets, equipment, etc., and on to poles, the elbow required and the stub-up out of the slab or earth shall be of plastic -coated rigid steel.



- PP. Branch circuit raceways run underground external to building foundation walls shall be run in raceways installed in accordance with the NEC, and shall be of a type approved by the NEC as "suitable for direct burial." Minimum raceway size shall be 1 inch.
- QQ. Raceways run underground, internal to building foundation walls shall be of a type, and installed by a method approved by the NEC.
- RR. Raceways that penetrate outside walls, ceilings from conditioned space or other similar condition shall be effectively sealed to prevent condensation from infiltrating humid air.
- SS. Where raceways pass through a below grade wall, from a conditioned interior building space, the raceway shall be sealed utilizing fittings similar and equal to OZ/GEDNEY type "FSK" thru-wall fitting with "FSKA" membrane clamp adapter if required.
- TT. All underground raceways shall be identified by underground line marking tape within the provisions of Section 260553. The tape to be located directly above the raceway and 6 to 8 inches below finished grade.

### 3.2 INTERFACE WITH OTHER PRODUCTS

- A. Install conduit to preserve fire resistance rating of partitions and other elements, using materials and methods under the provisions of Division 7.
- B. Route conduit through roof openings for piping and ductwork or through suitable roof jack with pitch pocket. Coordinate location with roofing installation specified under Division 7.

END OF SECTION

## **SECTION 260534 - BOXES**

### **PART 1 GENERAL**

#### **1.1 SECTION INCLUDES**

- A. Wall and ceiling outlet boxes.
- B. Pull and junction boxes.

#### **1.2 RELATED SECTIONS**

- A. Division 7: Firestopping.
- B. Division 8: Access Doors.
- C. Section 262726 - Wiring Devices: Wall plates in finished areas and floor box service fittings.
- D. Section 260529 – Supporting Devices.

#### **1.3 REFERENCES**

- A. NECA - Standard of Installation.
- B. NEMA FB 1 - Fittings and Supports for Conduit and Cable Assemblies.
- C. NEMA OS 1 - Sheet-steel Outlet Boxes, Device Boxes, Covers, and Box Supports.
- D. NEMA 250 - Enclosures for Electrical Equipment (1000 Volts Maximum).
- E. NFPA 70 - National Electrical Code.

#### **1.4 SUBMITTALS FOR REVIEW**

- A. Submittals: Procedures for submittals. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Product Data: Provide manufacturer's catalog information showing dimensions and configurations.

#### **1.5 SUBMITTALS FOR CLOSEOUT**

- A. Contract Closeout: Submittals for Project closeout. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Record actual locations and mounting heights of outlet, pull, and junction boxes on project record documents.

## 1.6 REGULATORY REQUIREMENTS

- A. Conform to requirements of NFPA 70.
- B. Provide Products listed and classified by testing firm acceptable to the authority having jurisdiction as suitable for the purpose specified and indicated.

## PART 2 PRODUCTS

### 2.1 OUTLET BOXES

- A. Sheet Metal Outlet Boxes: NEMA OS 1, galvanized steel.
  - 1. Junction, switch, receptacle and outlet boxes for interior use in dry locations shall be zinc coated or cadmium plated sheet steel, 4" square and 2-1/8" deep, unless otherwise indicated on the contract drawings. Smaller and shallower outlet boxes will be permitted only by special permission of the Architect/Engineer where such boxes are necessary due to structural conditions encountered. Where larger junction boxes are required, they shall be fabricated from No. 10, 12, 14 or 16 gauge sheet steel as required by the Underwriters Laboratories, Inc., and galvanized after fabrication. All junction boxes shall have screw fastened covers. Outlet boxes shall be provided with extension plaster rings where required by structural and finish conditions. Sheet steel boxes shall be as manufactured by Appleton, Raco, Steel City or Spring City.
  - 2. Luminaire and Equipment Supporting Boxes: Rated for weight of equipment supported; include 2 inch (13 mm) male fixture studs where required.
  - 3. Concrete Ceiling Boxes: Concrete type.
- B. Cast Boxes: NEMA FB 1, Type FD, cast ferrous alloy. Provide gasketed cover by box manufacturer. Provide threaded hubs. Cast boxes shall be by Crouse-Hinds, Appleton, O. Z. Gedney or Killark.
- C. Wall Plates for Finished Areas: As specified in Section 262726.

### 2.2 PULL AND JUNCTION BOXES

Sheet Metal Boxes: NEMA OS 1, galvanized steel.

## PART 3 EXECUTION

### 3.1 EXAMINATION

Verify locations of floor boxes and outlets prior to rough-in.

### 3.2 INSTALLATION

- A. Install boxes in accordance with NECA "Standard of Installation".
- B. Install in locations as shown on Drawings, and as required for splices, taps, wire pulling, equipment connections and compliance with regulatory requirements.

- C. Set wall mounted boxes at elevations to accommodate mounting heights indicated and specified in section for outlet device. Boxes are shown on Drawings in approximate locations unless dimensioned. Adjust box location up to 10 feet (3 m) if required to accommodate intended purpose. Install pull boxes and junction boxes above accessible ceilings and in unfinished areas only. Install boxes to preserve fire resistance rating of partitions and other elements, using approved materials and methods. Coordinate mounting heights and locations of outlets mounted above counters, benches, and backsplashes. Use flush mounting outlet box in finished areas. Use Erico Caddy RBS series, Raco 9001 or Cooper B-Line BB8-16 box mounting brackets to support flush mounting outlet boxes between studs.

### 3.3 ADJUSTING

- A. Contract Closeout: Adjust installed work under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Adjust flush-mounting outlets to make front flush with finished wall material.
- C. Install knockout closures in unused box openings.

### 3.4 CLEANING

- A. Contract Closeout: Clean installed work under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Clean interior of boxes to remove dust, debris, and other material.
- C. Clean exposed surfaces and restore finish.

END OF SECTION

## **SECTION 260535 - SURFACE METAL RACEWAYS**

### **PART 1 GENERAL**

#### **1.1 SECTION INCLUDES**

Surface metal raceways including base, cover, boxes, fittings, etc.

#### **1.2 RELATED SECTIONS**

Section 260529 – Supporting Devices.

#### **1.3 REFERENCES**

A. NECA (National Electrical Contractor's Association) Standard of Installation.

#### **1.4 SUBMITTALS**

A. Submittals: Procedures for submittals. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.

B. Product Data: Provide dimensions, knockout sizes and locations, materials, fabrication details, finishes, and accessories.

C. Manufacturer's Instructions: Indicate application conditions and limitations of use stipulated by Product testing agency specified under Regulatory Requirements. Include instructions for storage, handling, protection, examination, preparation, and installation of Product.

#### **1.5 QUALITY ASSURANCE**

Perform Work in accordance with NECA Standard of Installation.

#### **1.6 QUALIFICATIONS**

Manufacturer: Company specializing in manufacturing Products specified in this Section with minimum three years documented experience.

#### **1.7 REGULATORY REQUIREMENTS**

A. Conform to requirements of ANSI/NFPA 70.

B. Furnish products listed and classified by testing firm acceptable to authority having jurisdiction as suitable for purpose specified and shown.

### **PART 2 PRODUCTS**

#### **2.1 SURFACE METAL RACEWAY**

A. Manufacturers:

1. Wiremold 500 and 700 Series.
  2. Walker.
  3. Hubbell.
  4. Substitutions: Under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Description: Sheet metal channel with fitted cover, suitable for use as surface metal raceway.
- C. Finish: Buff enamel.
- D. Fittings, Boxes, and Extension Rings: Furnish manufacturer's standard accessories.
- E. Use: Installed in architectural millwork.

### PART 3 EXECUTION

#### 3.1 EXAMINATION

Verify that dimensions are correct and substrates are in proper condition to receive raceway. Do not proceed with installation until unsatisfactory conditions have been corrected.

#### 3.2 INSTALLATION

- A. Install Products in accordance with manufacturer's instructions.
- B. Use flat-head screws, clips, and straps to fasten raceway channel to surfaces. Mount plumb and level.
- C. Use suitable insulating bushings and inserts at connections to outlets and corner fittings.
- D. Install cover seals between adjoining sections of covers for a neat, aesthetic appearance.
- E. Install base, cover, boxes, fittings, wiring devices, accessories, etc., as necessary for a complete system.
- F. Close ends of wireway and unused conduit openings.
- G. Ground and bond raceway and wireway under provisions of Section 260526.

END OF SECTION

## **SECTION 260553 - ELECTRICAL IDENTIFICATION**

### **PART 1 GENERAL**

#### **1.1 SECTION INCLUDES**

- A. Wire and cable markers.
- B. Conduit markers.
- C. Wiring device plates marking.
- D. Underground warning tape.

#### **1.2 RELATED SECTIONS**

Division 9: Painting.

#### **1.3 REFERENCES**

ANSI/NFPA 70 - National Electrical Code.

#### **1.4 SUBMITTALS**

- A. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Product Data: Provide catalog data for nameplates, labels, and markers.
- C. Manufacturer's Instructions: Indicate application conditions and limitations of use stipulated by Product testing agency specified under regulatory requirements. Include instructions for storage, handling, protection, examination, preparation and installation of Product.

#### **1.5 REGULATORY REQUIREMENTS**

- A. Conform to requirements of ANSI/NFPA 70.
- B. Furnish products listed and classified by testing firm acceptable to authority having jurisdiction as suitable for purpose specified and shown.

### **PART 2 PRODUCTS**

#### **2.1 WIRE MARKERS**

- A. Description: Split sleeve type wire markers or approved equivalent.
- B. Locations: Each conductor at panelboard gutters, pull boxes, outlet and junction boxes, and each load connection.

C. Legend:

1. Power and Lighting Circuits: Branch circuit or feeder number as indicated on drawings.

## 2.2 CONDUIT, RACEWAY AND BOX MARKING

Paint visible surfaces of exposed junction and outlet boxes and covers of raceway systems above lay-in and other accessible ceilings. Paint all boxes and covers before installation. Paint exposed conduit and raceways at ten foot minimum intervals with a 6 inch wide band in accordance with the color scheme outlined above. Mark conduits at junction boxes above accessible ceilings with the panelboard and circuit numbers of the circuits contained in the raceway using a permanent black marking pen.

## 2.3 WIRING DEVICE PLATES MARKING

A. Description:

1. Adhesive backed, laminated plastic receptacle device plate labels identifying the circuit feeding the device. Labels shall be label machine printed, **black lettering on a clear background**, to indicate panel and circuit number and shall be Casio, Brother, T&B or approved equal.
2. Print circuit number on flag type plastic cable tie with a permanent marker (Sharpie, etc.) and attach to conductors in outlet box. Flag shall be readily visible upon removal of device plate.

B. Locations: Each receptacle device plate. Apply centered on the lower portion below the receptacle, parallel to the lower surface.

C. Legend: Typed labels to indicate panel and circuit number feeding the device (i.e., RPA-24).

## 2.4 UNDERGROUND WARNING TAPE

6 inch (150 mm) wide, 4 mils thick, minimum, permanent plastic tape compounded for direct burial, detectable type, colored bright yellow with suitable continuous warning legend describing buried electrical lines.

## PART 3 EXECUTION

### 3.1 PREPARATION

Degrease and clean surfaces to receive nameplates and labels.

### 3.2 APPLICATION

- A. Install receptacle identification labels at top of each device plate, parallel to upper surface.
- B. Identify conduit using field painting under provisions of Division 9.
- C. All empty conduit runs and conduit with conductors for future use shall be identified for use and shall indicate where they terminate. Identification shall be by tags with



string or wire attached to conduit or outlet.

- D. Update all existing panelboard directories where changes are made. Provide new panel schedule cards as required to maintain legibility.
- E. Identify underground conduits using one underground warning tape per trench at 6 - 8 inches below finished grade.
- F. Install adhesive backed labels only when ambient temperature and humidity conditions for adhesive use are within range recommended by manufacturer.

END OF SECTION

## **SECTION 262726 - WIRING DEVICES**

### **PART 1 GENERAL**

#### **1.1 SECTION INCLUDES**

- A. Wall switches.
- B. Wall box dimmers.
- C. Receptacles.
- D. Wall plates.

#### **1.2 DESCRIPTION**

Provide wiring devices in types, characteristics, grades, colors and electrical ratings for applications indicated which are third party testing agency listed and which comply with NEMA WD 1 and other applicable third party testing agency, NEMA and DSCC (Fed Spec) standards.

#### **1.3 RELATED SECTIONS**

Section 260534 - Boxes.

#### **1.4 REFERENCES**

- A. NECA - Standard of Installation.
- B. NEMA WD 1 - General Requirements for Wiring Devices.
- C. NEMA WD 6 - Wiring Device - Dimensional Requirements.
- D. NFPA 70 - National Electrical Code.
- E. Underwriters Laboratories (UL) 498.
- F. DSCC (Fed Spec) W-C-596G

#### **1.5 SUBMITTALS FOR REVIEW**

- A. Submittals: Procedures for submittals. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Product Data: Provide manufacturer's catalog information showing dimensions, colors, and configurations.

## 1.6 SUBMITTALS FOR INFORMATION

- A. Submittals: Submittals for information. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Submit manufacturer's installation instructions.

## 1.7 QUALIFICATIONS

Manufacturer: Company specializing in manufacturing the Products specified in this section with minimum three years documented experience.

## 1.8 REGULATORY REQUIREMENTS

- A. Conform to requirements of NFPA 70.
- B. Provide Products listed and classified by testing firm acceptable to the authority having jurisdiction as suitable for the purpose specified and indicated.

## PART 2 PRODUCTS

### 2.1 WALL SWITCHES

- A. Manufacturers:
  - 1. Hubbell Model HBL1221 Series.
  - 2. Leviton 1221.
  - 3. Pass and Seymour PS20AC1.
  - 4. Substitutions: Refer to provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Description: NEMA WD 1, third party testing agency listed, DSCC, heavy-duty, AC only, general-use, grounding type, back and side wired, single pole, three-way and four-way as indicated, snap switch with hex-head equipment grounding screw. Switches shall have a steel, nickel plated bridge with integral ground, one piece rivetless copper alloy spring contact arm and terminal plate and large silver cadmium oxide contacts. All switches shall have quiet operating mechanisms without the use of mercury switches. All switches shall be approved by a third party agency, approved for the voltage and current indicated.
- C. Body and Handle: Gray plastic with toggle handle.
- D. Indicator Light: Neon lighted handle type switch; red color handle. Voltage per system rating.
- E. Locator Light: Neon lighted handle type switch; green color handle. Voltage per system rating.
- F. Ratings:
  - 1. Voltage: 120-277 volts AC.
  - 2. Current: 20 amperes.

## 2.2 WALL BOX INCANDESCENT DIMMERS

- A. Manufacturers:
  - 1. Lutron.
  - 2. Leviton.
  - 3. Arrow Hart.
  - 4. Substitutions: Refer to provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Description: NEMA WD 1, third party testing agency, DSCC, Type I semiconductor dimmer for incandescent lamps.
- C. Body and Handle: Gray plastic with preset slider.
- D. Voltage: 120 volts.
- E. Power Rating: Match load shown on drawings; 600 watts minimum at 80% maximum load.

## 2.3 WALL BOX FLUORESCENT DIMMERS

- A. Manufacturers:
  - 1. Lutron.
  - 2. Leviton.
  - 3. Arrow Hart.
  - 4. Substitutions: Refer to provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Description: NEMA WD 1, third party testing agency, DSCC Type I semiconductor dimmer for fluorescent ballasts.
- C. Body and Handle: Gray plastic with preset slider.
- D. Voltage: 120 or 277 volts as required.
- E. Power Rating: Match load shown on drawings.

## 2.4 RECEPTACLES

- A. Manufacturers:
  - 1. Hubbell Model HBL 5362.
  - 2. Leviton 5362.
  - 3. Pass and Seymour 5362A.
  - 4. Substitutions: Refer to provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Description: NEMA WD 1, third party testing agency, DSCC, heavy-duty, 20 ampere, 120 volt, general use, duplex, straight blade, grounding type receptacle arranged for back and side wiring, with separate single or double grounding terminals. Receptacles shall have a full wrap around brass bridge with integral ground and standup double wipe contacts. Self grounding or automatic type grounding receptacles are not acceptable in lieu of receptacles with separate

grounding screw lugs and a direct, green insulated conductor connection to the equipment grounding system.

- C. Device Face and Body: Gray nylon or reinforced thermoplastic.
- D. Configuration: NEMA WD 6, type as specified and indicated.
- E. Convenience Receptacle: Type 5-20R.

## 2.5 GROUND FAULT CIRCUIT INTERRUPTERS (GFI)

- A. Manufacturers:
  - 1. Hubbell Model GF20GY\*LA. \* GY indicates gray device, revise model number if color other than gray is to be provided.
  - 2. Leviton.
  - 3. Pass and Seymour.
  - 4. Substitutions: Refer to provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Description: NEMA WD 1, third party testing agency, DSCC, heavy-duty, 20 ampere, 120 volt, general use, duplex, straight blade, grounding type receptacle arranged for back and side wiring, with separate single or double grounding terminals. Receptacles shall have a full wrap around brass bridge with integral ground and standup double wipe contacts. The electronic component's circuit board shall be all glass with a conformal coating. Self grounding or automatic type grounding receptacles are not acceptable in lieu of receptacles with separate grounding screw lugs and a direct, green insulated conductor connection to the equipment grounding system.
- C. Device Face and Body: Gray nylon or reinforced thermoplastic.
- D. Configuration: NEMA WD 6, type as specified and indicated.
- E. Convenience Receptacle: Type 5-20R.

## 2.6 WALL PLATES

- A. Manufacturers:
  - 1. Hubbell.
  - 2. Leviton.
  - 3. Pass and Seymour.
  - 4. Substitutions: Refer to provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Decorative Cover Plate: Single and combination, of types, sizes and with ganging and cutouts as indicated. Provide plates which mate and match with wiring devices to which attached. Material shall be smooth, 0.04" thick, type 302 Stainless Steel as manufactured by the device vendor.
- C. Weatherproof Cover Plate: Exterior mounted receptacles, and those noted to be weatherproof, shall be provided with weatherproof PVC transparent cover plates,

standard size, and shall be single or ganged as indicated on the contract drawings. Weatherproof plates shall be "approved" third party listed as "raintight while in use".

## PART 3 EXECUTION

### 3.1 EXAMINATION

- A. Ensure that outlet boxes are installed at proper height.
- B. Ensure that wall openings are neatly cut and will be completely covered by wall plates.
- C. Verify that branch circuit wiring installation is completed, tested, and ready for connection to wiring devices.

### 3.2 PREPARATION

- A. Provide extension rings to bring outlet boxes flush with finished surface.
- B. Clean debris from outlet boxes.

### 3.3 INSTALLATION

- A. Install in accordance with NECA "Standard of Installation".
- B. Install devices vertically, plumb and level.
- C. Install switches with OFF position down.
- D. Install receptacles with grounding pole on top. Install horizontally oriented receptacles with the grounding pole on the left.
- E. Receptacles installed over counters, backsplashes, etc., shall be mounted horizontally.
- F. Install wall dimmers to achieve full rating specified and indicated after derating for ganging as instructed by manufacturer.
- G. Do not share neutral conductor on load side of dimmers.
- H. Connect wiring device grounding terminal to branch circuit equipment grounding conductor.
- I. Install decorative plates on switch, receptacle, and blank outlets in finished areas. Schedule installation of finish plates after the surface upon which they are installed has received final finish.
- J. Connect switches by wrapping conductor around screw terminal.
- K. Connect receptacles by utilizing back wiring provisions only. Do not use side wire terminals.

- L. Install galvanized steel plates on outlet boxes and junction boxes in unfinished areas, above accessible ceilings, and on surface mounted outlets.
- M. Install protective rings on active flush cover service fittings.
- N. Provide adhesive backed, laminated plastic receptacle device plate labels identifying the circuit feeding the device. Labels shall be label machine printed to indicate panel and circuit number and shall be Casio, Brother, T&B or approved equal. See Section 260553 for additional requirements

### 3.4 INTERFACE WITH OTHER PRODUCTS

- A. Coordinate locations of outlet boxes provided under Section 260534 to obtain mounting heights specified and indicated on drawings.
- B. All wiring devices shall be installed at heights as required by the ADA
- C. Install wall switch 48 inches above finished floor, measured to top of device plate.
- D. Install convenience receptacle 18 inches above finished floor, measured to bottom of device plate, unless noted otherwise on the Drawings.
- E. Install convenience receptacle horizontally 6 inches above backsplash of counter, unless noted otherwise on the Drawings.
- F. Install dimmer 48 inches (1.2 m) above finished floor, measured to top of device of plate.
- G. Install telecommunications jack 18 inches (450 mm) above finished floor, measured to bottom of device plate, unless noted otherwise on the Drawings.
- H. Install telephone jack for side-reach wall telephone to position top of telephone at 54 inches (1.4 m) above finished floor, unless noted otherwise on the Drawings.
- I. Install telephone jack for forward-reach wall telephone to position top of telephone at 48 (1.2 m) above finished floor, unless noted otherwise on the Drawings.

### 3.5 FIELD QUALITY CONTROL

- A. Quality Control. As required under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Inspect each wiring device for defects.
- C. Operate each wall switch with circuit energized and verify proper operation.
- D. Verify that each receptacle device is energized.
- E. Test each receptacle device for correct polarity and for ground continuity.
- F. Test each GFCI receptacle device for correct operation.

3.6 ADJUSTING

- A. Contract Closeout: Adjust installed work under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Adjust devices and wall plates to be flush and level.

3.7 CLEANING

- A. Contract Closeout: Clean installed work under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Clean exposed surfaces to remove splatters and restore finish.

END OF SECTION



## **SECTION 265100 - INTERIOR LUMINAIRES**

### **PART 1 GENERAL**

#### **1.1 SECTION INCLUDES**

- A. Interior luminaires and accessories.
- B. Ballasts.
- C. Lamps.
- D. Luminaire accessories.

#### **1.2 RELATED SECTIONS**

- A. Section 260533 - Conduit.
- B. Section 260519 - Building Wire and Cable.
- C. Section 260534 - Boxes.
- D. Section 260526 - Grounding and Bonding.
- E. Section 260553 - Electrical Identification.

#### **1.3 REFERENCES**

- A. ANSI C78.379 - Electric Lamps - Incandescent and High-Intensity Discharge Reflector Lamps - Classification of Beam Patterns.
- B. ANSI C82.1& C82.11 - Ballasts for Fluorescent Lamps - Specifications.
- C. ANSI C82.4 - Ballasts for High-Intensity Discharge and Low Pressure Sodium Lamps (Multiple Supply Type).
- D. NEMA WD 6 - Wiring Devices-Dimensional Requirements.
- E. NFPA 70 - National Electrical Code.
- F. NFPA 101 - Life Safety Code.

#### **1.4 SUBMITTALS FOR REVIEW**

- A. Submittals: Procedures for submittals. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Shop Drawings: Indicate dimensions and components for each luminaire that is not a standard product of the manufacturer.

- C. Product Data: Provide dimensions, ratings, and performance data.

#### 1.5 SUBMITTALS FOR INFORMATION

- A. Submittals: Submittals for information. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Submit manufacturer's installation instructions. Indicate application conditions and limitations of use stipulated by Product testing agency specified under Regulatory Requirements. Include instructions for storage, handling, protection, examination, preparation, and installation of Product.

#### 1.6 SUBMITTALS FOR CLOSEOUT

- A. Contract Closeout: Submittals for project closeout. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Submit manufacturer's operation and maintenance instructions for each product.

#### 1.7 QUALIFICATIONS

Manufacturer: Company specializing in manufacturing the Products specified in this section with minimum three years documented experience.

#### 1.8 REGULATORY REQUIREMENTS

- A. Conform to requirements of NFPA 70.
- B. Conform to requirements of NFPA 101.
- C. Lighting systems shall comply with the 2012 North Carolina State Energy Code and North Carolina Senate Bill 668.
- D. Products: Listed and classified by testing firm acceptable to the authority having jurisdiction as suitable for the purpose specified and indicated.

#### 1.9 EXTRA PRODUCTS

- A. Furnish one replacement lamp for each incandescent and HID lamp type. Furnish one replacement fluorescent lamp for each 24 of each lamp type, but no less than one.
- B. Furnish two of each HID ballast type. Furnish one replacement fluorescent lamp ballast for each 24 of each type, but no less than one.

### PART 2 PRODUCTS

#### 2.1 LUMINAIRES

- A. Furnish Products as scheduled. Refer to relevant sections of the General and Supplemental General Conditions and Division 1 Specifications Sections for substitutions and product options.
- B. All lighting fixtures shall be approved by third party testing agencies and NFPA and shall bear their label.
- C. All fixtures shall have a stock, or standard finish unless otherwise specified. Fixtures subject to corrosive or damp environments shall have corrosion resistant hardware and finishes.
- D. All fixtures shall be installed complete with lamps.
- E. Lighting fixture types shall be furnished as required by the Lighting Fixture Schedule as indicated on the drawings. Catalog numbers are provided as a guide to the design and quality of fixture desired. Equivalent designs and equal quality fixtures of other manufacturers listed will be acceptable upon approval of the Architect/Engineer. The Contractor shall verify from the contract drawings the type ceilings or walls the fixture is to be used with and shall provide compatible mounting attachments and trim. Provide all accessories or additional materials required to maintain the ceiling fire rating as required by regulatory authorities.

## 2.2 FLUORESCENT BALLASTS

- A. Ballasts shall conform to the specifications of the Underwriters Laboratories and the American Standards Association and shall display labels and/or symbols of approval by the Underwriters Laboratories, and compliance with ANSI C82.11. Ballast manufacturer shall have at least ten years experience manufacturing electronic ballasts with a documentable low failure rate. The component parts of the ballasts shall be designed, fabricated, and assembled in accordance with the latest requirements of the National Electrical Code. To show compliance with all the above requirements, the ballast shall be marked "Class P" indicating approved integral ballast protection. No PCB Ballasts will be accepted.
- B. Ballasts shall:
  1. provide safe and reliable operation of the specified lamps.
  2. be programmed start electronic type, unless noted otherwise.
  3. have enclosure size the same as, or smaller than, magnetic ballast.
  4. operate at a frequency of not less than 20,000 hz.
  5. be sound rated "A".
  6. be warranted for a period of at least five years.
  7. be able to withstand line voltage transients in accordance with IEEE 587, Category A for normal and common modes; and shall meet FCC Rules and Regulations, part 18.
  8. have a minimum power factor not less than 0.90.
  9. have an input current total harmonic distortion less than 20 percent. Input current third harmonics shall not exceed ANSI recommendations (32% total harmonic distortion, 27.5% of the third triplets).
  10. be potted, manufactured in the U.S.A. and shall provide true parallel lamp, instant start operation.
  11. have a case temperature not to exceed 25° C. rise over 40° C. ambient.

12. be rated for operation at 0°F for exterior applications.

C. Ballast Minimum Characteristics when tested in accordance with ANSI C82.2 methods:

Lamp Type	Number of Lamps	Min. Ballast Factor	Max. Input Power
F32 T8 30 Watt	2	0.88	52
F32 T8 30 Watt	3	0.88	76
F32 T8 30 Watt	4	0.88	100
F54 T5/HO 54 Watt	2	1.00	117

D. Electromagnetic interference shall not be greater than that allowed by the FCC RR, Part 15, Subpart J and Part 18 for RF lighting devices. Light regulation shall be  $\pm$  10% input voltage variation. Flicker shall be 15% or less with any lamp suitable for the ballast. Lamp current crest factor shall be equal to, or less than, 1.7.

E. Multi-level switched fixtures shall have multiple ballasts or switchable ballasts.

### 2.3 HIGH INTENSITY DISCHARGE (HID) BALLASTS

A. Ballasts shall conform to the specifications of the Underwriters Laboratories, Inc. and American National Standard Institute (ANSI), and shall display their labels and/or symbols. They shall meet or exceed ANSI requirements for crest factors, starting currents, starting voltage and operating conditions.

B. Ballasts shall be of the peak lead auto-transformer type, high power factor, and a primary voltage regulator range of +10% for a +5% or less change in lamp wattage.

### 2.4 LAMPS

Lamps shall be indicated on the drawings and as manufactured by Phillips, General Electric, Sylvania, or approved equal. Incandescent lamps shall be rated 120 volts, unless otherwise indicated. Fluorescent lamps shall be 3500K except as noted on the drawings and/or specified. F032, T-8 fluorescent lamps shall be rated at 2950 minimum lumens initial output. HID lamps shall be as noted on the drawings. Coordinate all HID lamp operating color temperatures to minimize lamp color difference.

### 2.5 LENSES

Lenses shall be clear virgin acrylic material with uniform 3/16" square based female cone prisms aligned 45° to the length and width of the lens panel. Minimum prism depth shall be 0.080" with a nominal panel thickness of 0.156" and a minimum overall panel thickness of 0.150" to 0.160" inches.

## PART 3 EXECUTION

### 3.1 INSTALLATION

A. Install suspended luminaires using pendants supported from swivel hangers. Provide pendant length required to suspend luminaire at indicated height.

- B. Where a recessed fluorescent, high intensity, or downlight fixture replaces a section or part of an acoustical ceiling tile, or a section or part of a suspended gypsum board ceiling, the fixture shall be supported at two (2) diagonal corners to the steel frame of the building. Supports shall be provided with the same type of wire as used to support the lay-in ceiling track or GWB ceiling system. Attach one end of the wire to one corner of the fixture and the other end to the building's structural system. The lay-in or flange fixture shall then be screwed to the main runners of the lay-in ceiling track or GWB ceiling system at all four (4) corners using sheet metal screws (parabolic type fixtures shall be attached to the ceiling grid with approved clips). The Electrical Contractor shall be responsible for coordination work with the ceiling contractor; however, the ceiling contractor will provide framed openings for reception of lighting fixtures. All recessed fixtures shall be furnished with all necessary mounting accessories.
- C. Locate recessed ceiling luminaires as indicated on reflected ceiling plan.
- D. Install surface mounted luminaires and exit signs plumb and adjust to align with building lines and with each other. Secure to prevent movement.
- E. Exposed Grid Ceilings: Support surface mounted luminaires on grid ceiling directly from building structure. Provide auxiliary members spanning ceiling grid members to support surface mounted luminaires. Fasten surface mounted luminaires to ceiling grid members using bolts or screws.
- F. Install recessed luminaires to permit removal from below.
- G. Install recessed luminaires using accessories and firestopping materials to meet regulatory requirements for fire rating.
- H. Install wall mounted luminaires, emergency lighting units and exit signs at height as indicated on Drawings.
- I. Install accessories furnished with each luminaire.
- J. Connect luminaires, emergency lighting units and exit signs to branch circuit outlets provided under Section 260534 using flexible conduit.
- K. Make wiring connections to branch circuit using building wire with insulation suitable for temperature conditions within luminaire.
- L. Bond products and metal accessories to branch circuit equipment grounding conductor.
- M. Install specified lamps in each emergency lighting unit, exit sign, and luminaire.

### 3.2 FIELD QUALITY CONTROL

- A. Quality Assurance: Field inspection, testing and adjusting shall be as required under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.

- B. Operate each luminaire after installation and connection. Inspect for proper connection and operation.

### 3.3 ADJUSTING

- A. Contract Closeout: Adjust installed work as required under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Aim and adjust luminaires as directed.

### 3.4 CLEANING

- A. Contract Closeout: Clean installed work as required under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Clean electrical parts to remove conductive and deleterious materials.
- C. Remove dirt and debris from enclosures.
- D. Clean photometric control surfaces as recommended by manufacturer.
- E. Clean finishes and touch up damage.

### 3.5 DEMONSTRATION AND INSTRUCTIONS

- A. Contract Closeout: Demonstrate installed work as required under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Demonstrate luminaire operation for minimum of two hours.

### 3.6 PROTECTION OF FINISHED WORK

- A. Contract Closeout: Protect installed work as required under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Relamp luminaires that have failed lamps at Substantial Completion. Replace LED modules in which more than 5% of the LEDs have failed lamps at Final Acceptance of the Work.

END OF SECTION

## **SECTION 265200 - EMERGENCY LIGHTING**

### **PART 1 GENERAL**

#### **1.1 SUMMARY**

Section includes emergency egress lighting units.

#### **1.2 RELATED SECTIONS**

A. Section 260526 - Grounding and Bonding

#### **1.3 STANDARDS**

A. UL 924

B. NFPA 101 - Life Safety Code.

C. NFPA 70 - National Electrical Code.

D. North Carolina State Building Code including Energy Code Volume X.

E. NEMA - Standards

#### **1.4 SUBMITTALS FOR REVIEW**

A. Submittals: Procedures for submittals. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.

B. Shop Drawings: Indicate dimensions and components for each luminaire that is not a standard product of the manufacturer.

C. Product Data: Provide dimensions, ratings, and performance data.

#### **1.5 SUBMITTALS FOR INFORMATION**

A. Submittals: Submittals for information. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.

B. Submit manufacturer's installation instructions. Indicate application conditions and limitations of use stipulated by Product testing agency specified under Regulatory Requirements. Include instructions for storage, handling, protection, examination, preparation, and installation of Product.

#### **1.6 SUBMITTALS FOR CLOSEOUT**

A. Contract Closeout: Submittals for project closeout. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.

- B. Submit manufacturer's operation and maintenance instructions for each product.

## 1.7 QUALIFICATIONS

Manufacturer: Company specializing in manufacturing products specified in this section with minimum three years documented experience.

## 1.8 REGULATORY REQUIREMENTS

- A. Conform to requirements of NFPA 70.
- B. Conform to requirements of NFPA 101.
- C. Products: Listed and classified by testing firm acceptable to the authority having jurisdiction as suitable for the purpose specified and indicated. Products shall also meet or exceed the standards listed in Part 2.

## PART 2 PRODUCTS

### 2.1 GENERAL

- A. All lighting fixtures shall be listed as emergency lighting equipment and approved by third party testing agencies and NFPA and shall bear their label.
- B. All fixtures shall have a stock, or standard finish unless otherwise specified.
- C. All fixtures shall be completely self-contained, provided with maintenance free battery, automatic charger and other features. They shall be installed complete with lamps, batteries, etc. which shall be new and unused at time of final inspection of the project for acceptance.
- D. Lighting fixture types shall be furnished as required by the Lighting Fixture Schedule on the contract drawings and as herein specified. Catalog numbers are provided as a guide to the design and quality of fixture desired. Equivalent designs and equal quality fixtures of other manufacturers listed will be acceptable upon approval of the Architect/Engineer. The Contractor shall verify from the contract drawings the type of ceilings or walls the fixture is to be used with and shall provide compatible mounting attachments and trim. Provide all accessories or additional materials required to maintain the ceiling fire rating as required by regulatory authorities.
- E. Emergency lighting fixtures shall be as shown on the lighting fixture schedule on the contract drawings, and as herein specified.
- F. Warranty: The entire unit shall be warranted for three years. The battery must have an additional two more years pro-rated warranty. Warranty shall date from the date of final project acceptance and be included in the contract document.

### 2.2 EMERGENCY LIGHTING (EGRESS) UNITS

- A. Product Description: Self-contained incandescent emergency lighting unit automatically activated when the line voltage drops below 80%.



- B. Battery: Ten year normal life expectancy, 12 volt, sealed, maintenance-free, lead calcium type, with 1.5 hour minimum capacity at 50 watts load. Battery shall be a high temperature type with an operating range of 0° C. to 60° C., contain a resealable pressure vent and sintered positive and negative terminals. A low voltage disconnect switch shall be included if a Lead battery is used, to disconnect the battery from the load and prevent damage from a deep discharge during an extended power outage.
- C. Battery Charger: Automatic, solid state, full wave rectification, surge protected, current-limiting, dual-rate type, with filtered output of sufficient capacity to recharge discharged battery to full charge within twelve hours. Provide fused output circuit, low voltage battery disconnect, brownout and short circuit protection. Thermal protection shall sense circuitry temperature and adjust charge current to prevent overheating and charger failure. Thermal compensation shall adjust charger output to provide optimum charge voltage relative to ambient temperature. Regulated charge voltage shall maintain constant charge voltage over a wide range of line voltages. AC lockout circuit shall allow battery connection before AC power is applied and prevent battery damage due to deep discharge.
- D. Lamps: Two twenty (20) watt minimum, glass, sealed beam halogen type in steel or plastic housing. Heads shall rotate for aiming.
- E. Mounting: Surface wall or recessed ceiling as indicated by the drawings.
- F. Housing: White polycarbonate, with steel backbox/housing or steel with white finish. Wall mount unit with hinged faceplate and adjustable mounting hardware.
- G. Self-Diagnostics: Electronics shall automatically, or manually upon demand, conduct self test on battery condition (including actual discharge), charger, lamps and internal wiring integrity per NEC and NFPA at prescribed intervals. A pilot light shall indicate the unit is connect to AC power. Provide test switch and visual indicator(s) of unit operational condition including charger status, ready and service code. Test switch shall simulate operation of the unit upon loss of AC power by energizing lamps from the battery, and also exercise the transfer relay.
- H. Electrical Connection: Conduit connection.
- I. Input Voltage: Dual voltage input (120/277 volts).

## PART 3 EXECUTION

### 3.1 INSTALLATION

- A. Install surface-mounted emergency lighting units plumb and adjust to align with building lines and with each other. Secure to prevent movement.
- B. Install wall-mounted emergency lighting units at height as indicated.
- C. Install accessories furnished with each emergency lighting unit.
- D. Connect emergency lighting units to branch circuit outlets provided under this

Division as indicated.

- E. Exposed Grid Ceilings: Support surface mounted luminaires on grid ceiling directly from building structure. Provide auxiliary members spanning ceiling grid members to support surface mounted luminaires. Fasten surface mounted luminaires to ceiling grid members using bolts or screws.
- F. Make wiring connections to branch circuit using building wire with insulation suitable for temperature conditions within unit.
- G. Install specified lamps in each emergency lighting unit.
- H. Ground and bond emergency lighting units and exit signs under the provisions of Section 260526.
- I. Locate emergency lighting fixtures as indicated on reflected ceiling plan.
- J. Install recessed luminaires to permit removal from below.
- K. Install recessed luminaires using accessories and firestopping materials to meet regulatory requirements for fire rating.
- L. Install screws to secure recessed grid-supported luminaires in place.
- M. Install accessories furnished with each luminaire.

### 3.2 FIELD QUALITY CONTROL

- A. Quality Assurance: Field inspection, testing and adjusting shall be as required under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Operate each luminaire after installation and connection. Inspect for proper connection and operation.

### 3.3 ADJUSTING

- A. Contract Closeout: Adjust installed work as required under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Aim and adjust emergency lighting fixture heads to illuminate paths of egress.

### 3.4 CLEANING

- A. Contract Closeout: Clean installed work as required under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Clean electrical parts to remove conductive and deleterious materials.
- C. Remove dirt and debris from enclosures.

- D. Clean photometric control surfaces as recommended by manufacturer.
- E. Clean finishes and touch up damage.

### 3.5 DEMONSTRATION AND INSTRUCTIONS

- A. Contract Closeout: Demonstrate installed work as required under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Demonstrate normal luminaire operation for minimum of ninety minutes after the unit has been permanently installed and charged for a minimum of 24 hours. The battery run time test shall be completed a minimum of 10 days prior to final inspection by Architect and representatives of the North Carolina State Construction Office. Any unit which fails the test shall be repaired or replaced, and tested again. A copy of the test report shall be sent to the North Carolina State Construction Office, through the Architect.

### 3.6 PROTECTION OF FINISHED WORK

- A. Contract Closeout: Protect installed work as required under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Relamp emergency lighting units and exit signs that have failed lamps at Substantial Completion. Replace exit signs in which more than 5% of the LEDs have failed lamps at Substantial Completion.

END OF SECTION